


2430 "E" Street, N. W.
Washington, D. C.
21 August 1953

25X1A9a



25X1A9a

Dear Mr. [REDACTED]:

Receipt of your letter of 14 August 1953 enclosing shop drawings Nos. 530803, -A, and -B covering subject items is acknowledged and one copy of each returned herewith.

With respect to the change in the automatic transfer arrangement, the Contractor's proposal is acceptable subject to a credit for the difference in cost between the two arrangements, chiefly the omission of the main breaker in the emergency panel (Panel EM, shown on Drawing No. 530803).

In all other respects, reference shop drawings may be approved.

Very truly yours,



25X1A9a

Enclosures

Shop Drawings